



# LAWN IRRIGATION

Residential and Commercial Lawn Sprinkling Systems

- AN IRRIGATION PERMIT IS REQUIRED
- Irrigation Meters shall be installed between water main and domestic water meter. Connection MAY be made within the domestic meter pit. Compression Fittings are required.
- Lawn Irrigation water meters, require a separate Water Meter Pit.
- Deduct Meters are not Permitted.
- E.P.A. Approved Backflow Prevention Device required & must be located outside the house.
- Backflow Prevention Devices, Inlet and Outlet piping should be copper.
- Winter Blow-out should be located after Backflow Device. Stop Waste Valves are permitted.
- York #Y-502, Water Meter Yoke, is recommended for all installations.
- Transitions of Copper piping to PVC piping should have Metal Female fittings.
- The area between the curb and sidewalk is referred to as the Curb Lawn or the City Right of Way. All systems in this Right of Way are the responsibility of the owner.
- Curb Lawn Sprinkler Heads must be located within 1 foot of sidewalk, spraying toward the street, not into the street or over the sidewalk.
- Main Lawn Sprinkler heads must be on the House side of sidewalk spraying towards the house, not over the sidewalk.
- All controls, valves and wiring must be in main yard, NOT in the Right of Way.
- FINAL INSPECTION REQUIRED.

